

#### Jail AHU # 4 Replacement: Addendum # 1

- Controls:
  - All new JCI controls to include, SA sensor, RA sensor, MA sensor, Modulating Chilled water valve and Modulating Hot water valve
  - Supply fan speed, and status
  - Freeze Stat, Dirty Filter switch
- Hot and Cold-Water Valves:
  - New 2 way valves, ball isolation supply valve, Return valve circuit setter
  - CV valve rating to match new unit.
  - New chilled water and hot water modulating valves
- Balancing:
  - Air balance to match original design supply outdoor air cfm.
  - Chilled water balance and hot water balancing to match new unit requirements.
- Electrical contractor if needed:
  - B&L Electrical, 608-692-8374 Bob Lambert