

## County Jail AHU #4 Replacement Request for Bid

### Questions and Answers **AMENDED**

---

1. Please provide JCI allowance amount (control programming only).
  - a. Estimate, 3-5,000
  
2. What are the piping, ductwork, and insulation specifications for this project?
  - a. ashrae 90.1 and iecc, astm E84 25/50
  
3. Should a new condensate pump be provided with the new AHU?
  - a. No, floor drain right next to the unit pad.
  
4. Are new isolation valves to be provided on the supply and return of the coil connections?
  - a. Yes.